## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 3225-1404:105 Page 1 of 1

**CATEGORY**: Fire Dampers

LISTEE: C & S Air Products, 2824 N. Sylvania Ave., Fort Worth, TX 76111

Contact: Michael Beaver (817) 831-7038

**DESIGN**: Models FD-120, FSD-121, FSD-122, FSD-123, FSD-131, FSD-132; FD-320, FSD-

321, FSD-322 and FSD-323 single and multi blade type construction fire dampers with No. 16 or No. 20 galvanized or stainless steel frame and No. 16 galvanized or stainless steel blades. Refer to listee's data sheet for detailed product description

and operational considerations. Sizes of dampers are as follow:

<u>Construction</u>	Width, Inch		Height, Inch	
	Min.	Max.	<u>Min.</u>	Max.
Single section Multiple section	6 16	36 108	6 8	48 96
FSD-131, -132 (single only)	8	24	8	24

RATING: FSD-131, FSD-132: 1-1/2 hour, 1 hour (Corridor)

FD-120, FSD-121, -122, -123: 1-1/2 hour

FD-320, FSD-321, -322, -323:3 hour

**INSTALLATION**: In accordance with listee's printed installation instructions, applicable codes &

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification/rating and UL label.

APPROVAL: Listed as 1-hour, 1-1/2-hour and 3-hour fire-rated dampers. \*Intended for use with

approved damper operators. For vertical or horizontal installations.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing No. 3230-1404:106 for

leakage dampers.

**XLF**: 3225-0368:110

\*Rev. 11-06-2001



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 22, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager